

J. Tandler

CERRO COPPER & BRASS COMPANY

DIVISION OF CERRO CORPORATION

INTERNAL MEMORANDUM

OTHER ADDRESSEES - FOR INFORMATION

8-17

CC: J. W. Goldenberg
R. E. Conreux
File 1104

154052

Form HQ-10

SHOW NAME, TITLE AND CORPORATION OF ADDRESSEE AND ADDRESSOR

TO: Al Suhre

DATE: August 12, 1970

FROM: Bill Graff

SUBJECT:

On the attached Dwg. 1104-G-30, I've indicated the point at which the 10" well water line is leaking. Materials on the second floor of the Concrete Building just under this pipe are being damaged because of the water on the floor. The floor drain is stopped up and should be opened also. Since this 10" well water line serves no purpose beyond the 1" Tankhouse take-off, I suggest we cap off this pipe and remove the disconnected section to the Concrete Building.

Bill Graff

BG/as

*SPOKE TO Bill re
POSSIBLE SERVICE TO
COPPER BEAST?*

C03338